



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)
National Highways Authority of India
(Ministry of Road Transport & Highways, Government of India)
क्षेत्रीय कार्यालय, मदुरै / Regional Office, Madurai

दूसरा व तीसरी तल, विजय कृष्ण प्लाज़ा, संख्या-1, लेक एरिया, मेलूर मेन रोड, माट्टुतावनी, मदुरै-625 007
2nd & 3rd Floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai-625 107
दूरभाष/ Tele : +91-452-258 8999 वेब/Website : www.nhai.gov.in ई-मेल/ E-mail : romadurai@nhai.org



NHAI/15018/3.7/04/2022/RO-Madurai/2771

07th December, 2022

INVITATION OF PUBLIC COMMENTS

Sub: NHAI - Madurai Region - PIU-Tuticorin - Tuticorin - Tirunelveli section of NH 7A - Proposal for Erection of 110 KV SC Overhead line crossing at km 36+200 of NH- 7A - Proposal submitted by Superintending Engineer, TANTRANSCO, Tirunelveli- In-Principle Approval Requested - Public Comments Invited - Reg.

The proposal received from PD, PIU-Tuticorin vide letter NHAI/PIU/TUTY/NH-7A/2022/888 dated 20.07.2022 thereby requesting Permission for Erection of 110KV SC Overhead transmission line Crossing at Km.36+200 in Tuticorin - Tirunelveli section of NH 7A in the State of Tamil Nadu proposed by by Superintending Engineer, TANTRANSCO, Tirunelveli.

2) The alignment proposed by Executive Engineer, TANTRANSCO, Tirunelveli. requesting Permission for Erection of 110KV SC overhead transmission line Crossing at Km.36+200 in Tuticorin - Tirunelveli section of NH 7A in the State of Tamil Nadu as detailed under;

Stretch in Km	Length in Meters	Remarks
Across NH-7A: At Km 36+200 to 36+000	45	Erection of 110KV SC line tower with Panther conductor

3) As mentioned in the PD letter, the ROW is 45 m at Km 36+200. As mentioned in the proposal, the Overhead tower are to be erected across NH at Km 36+200 to Km 36+000.

4) In this instant proposal, the as certified by PD, Tuticorin Vertical Clearance for the proposed erection overhead electrical 110KV overhead Transmission line is 14.25 m.

5) Superintending Engineer, TANTRANSCO, Tirunelveli has furnished necessary undertaking to the effect that they will relocate the Over Head Transmission line as and when requested by the NHAI at their own cost. It is also mentioned that, the proposed erection work of 110KV Over Head Transmission line across NH will not cause damage to any other utility, if damaged they will pay the losses either to NHAI or to the concerned agency as per Ministry Guidelines dated 22.11.2016.

-1-

(Signature)

National Highways Authority of India

NHAI/15018/3.7/04/2022/RO-Madurai/2771

07th December, 2022

6) Accordingly, As per the MoRTH guidelines vide letter No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016. The application is being uploaded on public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

In view of the above, comments of the public on the above proposal is invited to the below mentioned address:

The Regional Officer,
National Highways Authority of India,
No. 3rd Floor, Vijay Krishna Plaza,
No.1, Lake Area, Melur Main Road, Mattuthavani,
Madurai - 625 007.

This is issued with approval of Regional Officer-Madurai.

Yours Faithfully,



(Mahendra Meena)
Dy. Manager (Tech)

Copy to:

1. The NIC, New Delhi - for uploading in the Ministry's website.
2. The PD, Tuticorin - for information.